



**NOTES:**

- 1) ALL MECHANICAL JOINTS SHALL BE RESTRAINED AS SPECIFIED IN SECTION 9-30.2(6) OF THE STANDARD SPECIFICATIONS.
- 2) MINIMUM TRENCH DEPTH IS 4'-10". MINIMUM DEPTH MAY INCREASE WHEN HYDRANTS ARE INSTALLED ON DISTRIBUTION MAINS LARGER THAN 8" IN DIAMETER, OR WHEN THE DISTRIBUTION MAIN HAS MORE THAN 4' OF COVER.
- 3) GRADELOK OR EQUIVALENTS SHALL BE USED WHEN NECESSARY TO MAINTAIN 2" BETWEEN THE SIDEWALK FLANGE AND THE FINISHED GRADE.
- 4) STORZ COUPLING SHALL BE 5" STORZ X 4.5" N.S.T., 1/4 TURN.

**HYDRANT CONNECTIONS**

APPROVED BY:

County Engineer:

DATE:

3/20/2003

REVISION:

DESCRIPTION:

DATE:

K.P.

STANDARD REVIEW

02-28-03

STANDARD PLAN

W-4

SHEET 1 OF 1

FILE NAME: G:\USERS\STANDARD\WATER\W4

