



NOTE:

1. CLEANOUT PIPE AND FITTINGS SHALL BE THE SAME DIAMETER AS SIDE SERVICE PIPE.
2. PROVIDE MIN. 2" SEPARATION BETWEEN BOTTOM OF LAMPHOLE COVER AND TOP OF PVC CAP.

**TYPICAL CLEANOUT**



APPROVED BY:

*Joe Stump*  
Utilities Manager:

9/12/06  
DATE:

REVISION:	DESCRIPTION:	DATE:

**SEWER PLAN**

**SS-8**

**SHEET 1 OF 1**

FILE NAME: