

Swimming Pool Log Sheet

Pool Name _____ Month _____ Year _____ Size of Pool (gallons) _____ Flow Rate Required (GPM) _____
 Type of Disinfectant _____ Minimum of 1.5 PPM if inorganic chlorine, 2.0 PPM if stabilized or organic, and 2.5 PPM if Bromine.

		Daily Tests					Weekly Tests		Chemicals Added		Maintenance & Notes	
Date	Water Clarity	Disinfectant PPM	Combined Chlorine < 50% free	pH 7.2-8.0	Flow GPM	Alkalinity Rec. Range 60-160 PPM	Cyanuric Acid if used < 90	Quantity of Disinfectant Added	Other Chemicals Added	Back-wash	Vacuum or Brush	Contaminant Episode
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												

Date	Daily Tests				Weekly Tests			Chemicals Added				Maintenance & Notes		
	Water Clarity	Disinfectant PPM	Combined Chlorine < 50% free	pH 7.2-8.0	Flow GPM	Alkalinity Rec. Range 60-160 PPM	Cyanuric Acid if used < 90	Quantity of Disinfectant Added	Other Chemicals Added	Back- wash	Vacuum or Brush	Contaminant Episode		
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														