

Pool & Spa Inspection checklist

WATER QUALITY				
1	2	3	#	Description
			0111	Disinfectant Low*
			0121	Disinfectant High*
			0130	Total chlorine
			0211	pH Low*
			0221	pH High*
			0410	Clarity- hazy*
			0510	Spa temp >104 <106*
			0600	Cyanuric acid
			0000	Alkalinity
			0300	Test kit

POOL ACCESS AND CONTROL				
			0800	Barrier height*
			0810	Barrier construction*
			0830	Entrances*
			5500	Pool not secured*
			5000	Supervision*
			5100	Pool signs

EMERGENCY EQUIPMENT				
			4200	Phone*
			4210	Spa shutoff & alarm*
			4400	Reach pole with hook
			4400	Throwing device (ring)
			4500	First aid kit
			4500	Emergency blanket
Lifeguarded pools only				
			3820	Lifeguard attentive*
			4300	Rescue tubes
			4300	Backboards

RECORDS				
			5600	Permit
			5400	Operations manual
			5300	Pool records
			3900	Training certifications
			5300	Accident/injury reports
			4000	Lifeguard drills
			5110	Notification of Conditions for use
			5700	Referrals and notes

POOL STRUCTURE				
1	2	3	#	Description
			0900	Main drain secure*
			1300	Diving boards
			1400	Starting blocks
			1200	Handrails secure
			1200	Steps color contrast
			1010	Skimmers/overflow
			1020	Missing weirs
			1030	Equalizer lines - entrap
			1100	Ladders and stairs
			0700	Walking surfaces
			2600	Lighting adequate
			2700	Lighting repair
			2800	Ventilation
			3300	Pool surface smooth
			3400	Pool surface color
			3700	Pool surface clean
			3500	Depth markings
			3600	Float/marking line

PUMP ROOM				
			1700	Pump/filter failure*
			1800	Pump/filter - maintained
			2100	Automatic disinfection
			2500	Chemical interlocks
			1900	Hair catcher
			1910	Extra filter cartridges
			1600	No Flow meter
			1610	Flow meter inoperative
			1500	Turnover
			2000	Pump room access
			2010	Pump room locked
			2300	Chemical storage
			4700	Water supply X-connect
			4800	Air gap - backwash
			4600	Approved water
			4900	Approved sewer

LOCKER ROOM				
			2900	Available & functional
			2910	Lockers/diaper stations
			3000	Clean & sanitary
			3100	Toilets/showers/sinks
			3200	Shower temp > 120

ACTION LEVELS FOR DISINFECTANTS											
POOLS			0100			0130			SPAS		
Type	pH	Min	Close	Max	Close	Type	pH	Min	Close	Max	Close
Chlorine	7.2	1.5	< 0.6	10.0	15.0	Chlorine	7.2	3.0	< 1.3	10.0	> 15.0
	7.5	1.5	< 0.8	10.0	15.0		7.5	3.0	< 1.7	10.0	> 15.0
	7.8	1.5	< 1.3	10.0	15.0		7.8	3.0	< 2.5	10.0	> 15.0
Sun stable chlorine	7.2	2.0	< 0.8	10.0	15.0	Sun stable chlorine	7.2	3.5	< 1.5	10.0	> 15.0
	7.5	2.0	< 1.1	10.0	15.0		7.5	3.5	< 2.0	10.0	> 15.0
	7.8	2.0	< 1.7	10.0	15.0		7.8	3.5	< 2.9	10.0	> 15.0
Bromine	7.2	2.5	< 2.3	10.0	15.0	Bromine	7.2	4.0	< 3.5	10.0	> 15.0
	7.5	2.5	< 2.3	10.0	15.0		7.5	4.0	< 3.6	10.0	> 15.0
	7.8	2.5	< 2.3	10.0	15.0		7.8	4.0	< 3.9	10.0	> 15.0

POOL CLOSURE ITEMS AND CODES			
0110	Inadequate Disinfectant	0120	Excess disinfectant (15.0 ppm or more)
0210	pH at 6.8 or less	0220	pH at 8.2 or above
0400	Water clarity – main drain not visible	0500	Spa Temp greater than 106
0900	Broken, loose or missing drain covers	0920	Single drain w/o additional entrapment protection (SVRS or other)
0925	Spa w/o emergency shut off	1015	Overflow system not functioning
1030	Equalizer line w/o entrapment protection	1700	Pumps not operating
1710	Filters not operating	3800	Lifeguards not present
4210	Emergency shut off or alarm not working	5000	Inadequate supervision
5900	Imminent hazard	0830	Barrier closures—not self-closing**
		0840	not self-latching**
		0850	pool not lockable **
5500	Pool not secured during non-use		

VGB Evaluation			
New covers installed		Install date	
Cover spec sheet/instructions		Max flow calc by design pro	
Installer signature		Sump documentation	
Single Drain Evaluation			
Unblockable drain with shut-off		SVRS installed & tested	

Inspector notes:
